

Voluntary Product Accessibility Template®

Version 1.3

The purpose of the **Voluntary Product Accessibility Template**, or **VPAT**[™], is to assist Federal contracting officials and other buyers in making preliminary assessments regarding the availability of commercial "Electronic and Information Technology" products and services with features that support accessibility. Autodesk provides this information to help our customers understand the accessibility features of this Autodesk product in the context of the Section 508 standards. This was done with the intent to enable agencies to be compliant with the Section 508 regulations. This document is not intended to be a certification of compliance.

The first table of the Template provides a summary view of the Section 508 Standards. The subsequent tables provide more detailed views of each subsection. There are three columns in each table. Column one of the Summary Table describes the subsections of subparts B and C of the Standards. The second column describes the supporting features of the product or refers you to the corresponding detailed table, e.g., "equivalent facilitation." The third column contains any additional remarks and explanations regarding the product. In the subsequent tables, the first column contains the lettered paragraphs of the subsections. The second column describes the supporting features of the product with regard to that paragraph. The third column contains any additional remarks and explanations regarding the product.

Date: January 21st, 2016

Name of Product: Autodesk® Moldflow Insight 2017

Contact for more Information (name/phone/email):

415-507-5000 business.services@autodesk.com

Summary Table

$\mathbf{VPAT}^{\mathsf{TM}}$

Voluntary Product Accessibility Template[®]

Criteria	Supporting Features	Remarks and explanations
Section 1194.21 Software Applications and Operating Systems	Supports with Exceptions	
Section 1194.22 Web-based Internet Information and Applications	Not Applicable	
Section 1194.24 <u>Video and Multi-media</u> <u>Products</u>	Not Applicable	
Section 1194.31 <u>Functional Performance</u> <u>Criteria</u>	Supports with Exceptions	
Section 1194.41 <u>Information</u> , <u>Documentation</u> and <u>Support</u>	Completed	

Section 1194.21 Software Applications and Operating Systems – Detail

VPAT™ Voluntary Product Accessibility Template®

Criteria	Supporting Features	Remarks and explanations
(a) When software is designed to run on a system that has a keyboard, product functions shall be executable from a keyboard where the function itself or the result of performing a function can be discerned textually.	Supports with Exceptions	All of the pull-down and context-menu commands can be accessed using the keyboard. A mouse is required to select an object in the 3-D display area.
(b) Applications shall not disrupt or disable activated features of other products that are identified as accessibility features, where those features are developed and documented according to industry standards. Applications also shall not disrupt or disable activated features of any operating system that are identified as accessibility features where the application programming interface for those accessibility features has been documented by the manufacturer of the operating system and is available to the product developer.	Supports	Autodesk Moldflow Insight 2017 does not make any changes to hardware or system settings.
(c) A well-defined on-screen indication of the current focus shall be provided that moves among interactive interface elements as the input focus changes. The focus shall be programmatically exposed so that Assistive Technology can track focus and focus changes.	Supports with Exceptions	Windows Narrator (Assistive Technology) exposed majority of on-screen activities. The Tab key can be used to change focus on different object controls. Most dialog boxes have a well-defined indicator of focus.

	T.	
(d) Sufficient information about a user interface element including the identity, operation and state of the element shall be available to Assistive Technology. When an image represents a program element, the information conveyed by the image must also be available in text.	Supports with Exceptions	Majority of UI program elements represented by an image or icon have a tooltip. Specific elements appear as text but behave like a button or combo box.
(e) When bitmap images are used to identify controls, status indicators, or other programmatic elements, the meaning assigned to those images shall be consistent throughout an application's performance.	Supports	Bitmap images and actions associated with them are generally consistent.
(f) Textual information shall be provided through operating system functions for displaying text. The minimum information that shall be made available is text content, text input caret location, and text attributes.	Supports with Exceptions	All text inputs have caret indicator.
(g) Applications shall not override user selected contrast and color selections and other individual display attributes.	Support	Autodesk Moldflow Insight 2017 does not override individual display attributes.
(h) When animation is displayed, the information shall be displayable in at least one non-animated presentation mode at the option of the user.	Not Applicable	Animations are not available in the product.
(i) Color coding shall not be used as the only means of conveying information, indicating an action, prompting a response, or distinguishing a visual element.	Support with Exceptions	For some objects, the only way to determine that an object is selected is by color. Attributes, checked elements, and error indicators depend on colors.
(j) When a product permits a user to adjust color and contrast settings, a variety of color selections capable of producing a range of contrast levels shall be provided.	Not Applicable	Does not allow the user to select the colour.
(k) Software shall not use flashing or blinking text, objects, or other elements having a flash or blink frequency greater than 2 Hz and lower than 55 Hz.	Supports	Autodesk Moldflow Insight 2017 does not use flash or blinking text. Text is scrolled at various speeds with ability to return to previous text.
(I) When electronic forms are used, the form shall allow people using Assistive Technology to access the information, field elements, and functionality required for completion and submission of the form, including all directions and cues.	Supports	Autodesk Moldflow Insight 2017 does not use electronic forms.

Section 1194.22 Web-based Internet information and applications – Detail

VPATTM

Voluntary Product Accessibility Template®

Criteria	Supporting Features	Remarks and explanations
(a) A text equivalent for every non-text element shall be provided (e.g., via "alt", "longdesc", or in element content).	Not Applicable	
(b) Equivalent alternatives for any multimedia presentation shall be synchronized with the presentation.	Not Applicable	
(c) Web pages shall be designed so that all information conveyed with color is also available without color, for example from context or markup.	Not Applicable	
(d) Documents shall be organized so they are readable without requiring an associated style sheet.	Not Applicable	
(e) Redundant text links shall be provided for each active region of a server-side image map.	Not Applicable	
(f) Client-side image maps shall be provided instead of server-side image maps except where the regions cannot be defined with an available geometric shape.	Not Applicable	
(g) Row and column headers shall be identified for data tables.	Not Applicable	
(h) Markup shall be used to associate data cells and header cells for data tables that have two or more logical levels of row or column headers.	Not Applicable	
(i) Frames shall be titled with text that facilitates frame identification and navigation	Not Applicable	
(j) Pages shall be designed to avoid causing the screen to flicker with a frequency greater than 2 Hz and lower than 55 Hz.	Not Applicable	

(k) A text-only page, with equivalent information or functionality, shall be provided to make a web site comply with the provisions of this part, when compliance cannot be accomplished in any other way. The content of the text-only page shall be updated whenever the primary page changes.	Not Applicable	
(I) When pages utilize scripting languages to display content, or to create interface elements, the information provided by the script shall be identified with functional text that can be read by Assistive Technology.	Not Applicable	
(m) When a web page requires that an applet, plug-in or other application be present on the client system to interpret page content, the page must provide a link to a plug-in or applet that complies with §1194.21(a) through (I).	Not Applicable	
(n) When electronic forms are designed to be completed on-line, the form shall allow people using Assistive Technology to access the information, field elements, and functionality required for completion and submission of the form, including all directions and cues.	Not Applicable	
(o) A method shall be provided that permits users to skip repetitive navigation links.	Not Applicable	
(p) When a timed response is required, the user shall be alerted and given sufficient time to indicate more time is required.	Not Applicable	

Note to 1194.22: The Board interprets paragraphs (a) through (k) of this section as consistent with the following priority 1 Checkpoints of the Web Content Accessibility Guidelines 1.0 (WCAG 1.0) (May 5 1999) published by the Web Accessibility Initiative of the World Wide Web Consortium: Paragraph (a) -1.1, (b) -1.4, (c) -2.1, (d) -6.1, (e) -1.2, (f) -9.1, (g) -5.1, (h) -5.2, (i) -12.1, (j) -7.1, (k) -11.4.

Section 1194.24 Video and Multi-media Products – Detail VPAT™

Voluntary Product Accessibility Template®

Criteria	Supporting Features	Remarks and explanations
a) All analog television displays 13 inches and larger, and computer equipment that includes analog television receiver or display circuitry, shall be equipped with caption decoder circuitry which appropriately receives, decodes, and displays closed captions from broadcast, cable, videotape, and DVD signals. As soon as practicable, but not later than July 1, 2002, widescreen digital television (DTV) displays measuring at least 7.8 inches vertically, DTV sets with conventional displays measuring at least 13 inches vertically, and stand-alone DTV tuners, whether or not they are marketed with display screens, and computer equipment that includes DTV receiver or display circuitry, shall be equipped with caption decoder circuitry which appropriately receives, decodes, and displays closed captions from broadcast, cable, videotape, and DVD signals.	Not Applicable	
(b) Television tuners, including tuner cards for use in computers, shall be equipped with secondary audio program playback circuitry.	Not Applicable	

(c) All training and informational video and multimedia productions which support the agency's mission, regardless of format, that contain speech or other audio information necessary for the comprehension of the content, shall be open or closed captioned.	Not Applicable	
(d) All training and informational video and multimedia productions which support the agency's mission, regardless of format, that contain visual information necessary for the comprehension of the content, shall be audio described.	Not Applicable	
(e) Display or presentation of alternate text presentation or audio descriptions shall be user-selectable unless permanent.	Not Applicable	

Section 1194.31 Functional Performance Criteria – Detail VPAT™

Voluntary Product Accessibility Template®

Criteria	Supporting Features	Remarks and explanations
(a) At least one mode of operation and information retrieval that does not require user vision shall be provided, or support for Assistive Technology used by people who are blind or visually impaired shall be provided.	Does Not Support	
(b) At least one mode of operation and information retrieval that does not require visual acuity greater than 20/70 shall be provided in audio and enlarged print output working together or independently, or support for Assistive Technology used by people who are visually impaired shall be provided.	Supports	No audio is available in the product. Autodesk Moldflow Insight 2017 adjusts the UI to system font size settings. Autodesk Moldflow Insight 2017 works well with Microsoft Magnifier (Assistive Technology).
(c) At least one mode of operation and information retrieval that does not require user hearing shall be provided, or support for Assistive Technology used by people who are deaf or hard of hearing shall be provided	Supports	Autodesk Moldflow Insight 2017 does not require user hearing to operate the software. No audio is provided by the product beyond the use of standard operating system alerts that can be displayed visually using Microsoft Accessibility settings.

(d) Where audio information is important for the use of a product, at least one mode of operation and information retrieval shall be provided in an enhanced auditory fashion, or support for assistive hearing devices shall be provided.	Does Not Support	Autodesk Moldflow Insight 2017 does not require user hearing to operate the software. No audio is provided by the product beyond the use of standard operating system alerts that can be displayed visually using Microsoft Accessibility settings. There are short instructional videos that have sound, but the information in those videos is also available in other user assistance and is not required to operate the system. Transcripts are not provided
(e) At least one mode of operation and information retrieval that does not require user speech shall be provided, or support for Assistive Technology used by people with disabilities shall be provided.	Supports	Autodesk Moldflow Insight 2017 does not require user speech to operate the software.
(f) At least one mode of operation and information retrieval that does not require fine motor control or simultaneous actions and that is operable with limited reach and strength shall be provided.	Supports with Exceptions	Keyboard navigation is provided with majority of menu commands. All non-keyboard accessible commands can be executed with a series of mouse clicks. The ViewCube® functionality allows manipulation of objects on the graphic screen with a single mouse button. ALT text equivalents of ribbon button text are provided, but audio versions are not supported.

Section 1194.41 Information, Documentation and Support – Detail

VPATTM

Voluntary Product Accessibility Template®

Criteria	Supporting Features	Remarks and explanations
(a) Product support documentation provided to end- users shall be made available in alternate formats upon request, at no additional charge	Supports	The documentation is available in the html format on http://www.autodesk.com
(b) End-users shall have access to a description of the accessibility and compatibility features of products in alternate formats or alternate methods upon request, at no additional charge.	Supports	This document is posted on our website at http://www.autodesk.com.
(c) Support services for products shall accommodate the communication needs of end-users with disabilities.	Supports	Support services options are available via webpage, e-mail, fax, or phone. Direct in-person support is also available through resellers.



Voluntary Product Accessibility Template and VPAT are registered trademarks or trademarks of Information Technology Industry Council.

Autodesk and [Autodesk Simulation 2017] are registered trademarks or trademarks of Autodesk, Inc., or its subsidiaries and/or affiliates in the USA and/or other /countries. All other brand names, product names, or trademarks belong to their respective holders. Autodesk reserves the right to alter product offerings and specifications at any time without notice, and is not responsible for typographical or graphical errors that may appear in this document. © 2016 Autodesk, Inc. All rights reserved.